VEX1000 Wiring diagram

EXcon+ automatic
EXcon+ automatik
Système de règulation EXcon+



EXHAUSTO A/S
Odensevej 76 · DK-5550 Langeskov
Tel. +45 65661234 · exhausto@exhausto.dk
www.exhausto.dk

a member of
Soler&Palau Ventilation Group

EXHAUSTO

VEX1000 - Customized (1x230VAC FANS)

2028066

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	1
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	0
Drawing number: 2028066	Page Title: Project information	Revision:	F	Scale:	1:1	Next page:	2
		Replaces revision:	D	Format:	A3	Pages in total:	40

Page	Title (en)	Titel (da)	Titel (sv)	Last edit
1	Project information	Projektinformation	Projektinformation	04-08-2026
4	Standards	Standarder	Standarder	17-08-2026
5	Standards	Standarder	Standarder	17-08-2026
6	Component overview	Komponentoversigt	Komponentöversikt	17-08-2026
9	Principles for all configuration options	Principper for alle konfigurationsmuligheder	Principer för alla konfigurationsalternativ	21-07-2026
10	Basic control panel 3x400V	Grundlæggende styretavle 3x400V	Grundläggande kontrollpanel 3x400V	06-08-2026
11	Supplementary selections	Supplerende tilvalg	Kompletterande tillval	06-08-2026
12	Control panel terminals	Styretavlens klemmer	Kontrollpanel plintar	06-08-2026
20	Main current	Hovedstrøm	Huvudström	06-08-2026
21	Power analyzers - 3 phase	Effektanalysatorer – 3-faset	Effektanalysatorer – 3-fas	06-08-2026
22	Pilot current	Styrestrøm	Styrström	05-08-2026
23	Standard - Modbus connections	Standard - Modbus-tilslutninger	Standard - Modbus-anslutningar	06-08-2026
24	Standard - Fan & Rotor/Bypass controls	Standard - Ventilator- og rotor-/bypassstyring	Standard - Fläkt- & rotor/bypass-reglering	06-08-2026
25	Standard - Dampers	Standard - Spjæld	Standard - Spjäll	06-08-2026
26	Options - Dampers	Tilvalg - Spjæld	Tillval - Spjäll	05-08-2026
27	Options - Pre-heating controls	Tilvalg - Forvarmestyring	Tillval - Förvärmningsstyrning	05-08-2026
28	Options - Post-heating controls	Tilvalg - Eftervarmestyring	Tillval - Eftervärmningsstyrning	05-08-2026
29	Options - HW/CW/CO controls	Tilvalg - HW/CW/CO-styring	Tillval - HW/CW/CO-styrning	05-08-2026
30	Options - Temperature & CO2 sensors	Tilvalg - Temperatur- og CO2-sensorer	Tillval - Temperatur- och CO2-givare	05-08-2026
31	Standard - Customer connections	Standard - Kundetilslutninger	Standard - Kundanslutningar	17-08-2026
40	Standard - Dual PTH 1	Standard - Dual PTH 1	Standard - Dual PTH 1	29-07-2026
41	Standard - Dual PTH 2	Standard - Dual PTH 2	Standard - Dual PTH 2	05-08-2026
42	Option - ALC™ - Rotor deicing - HR temperature	Tilvalg - ALC™ - Rotorafrimning - VGV-temperatur	Tillval - ALC™ - Rotoravfrostning - ÅV-temperatur	05-08-2026
43	Option - Counter-flow deicing - HR temperature	Tilvalg - Modstrømsafrimning - Varmegenvindingstemperatur	Tillval - Motströmsavfrostning - Återvinningstemperatur	29-07-2026
50	Option – Coil control box layout	Option - Layout af styreboks til flader	Tillval - Layout för batteristyrboxen	28-07-2026
51	Option - Combi Coil (CO)	Tilvalg - Kombiflade (CO)	Tillval - Kombibatteri (CO)	04-08-2026
52	Option - Direct Expansion Heat pump (DX)	Tilvalg - Direkte ekspansion varmepumpe (DX)	Tillval - Direkt expansion värmepump (DX)	04-08-2026
53	Option - Direct Expansion Cooling (DX)	Tilvalg - Direkte ekspansionskøling (DX)	Tillval - Direkt expansionskylning (DX)	04-08-2026
PARTS	Part list for active components -A1	Stykliste over aktive komponenter -A1	Stycklista över aktiva komponenter -A1	06-08-2026

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	2
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	1
Drawing number: 2028066	Page Title: Table of Contents	Revision:	F	Scale:	1:1	Next page:	4
		Replaces revision:	D	Format:	A3	Pages in total:	40

Identification of wires by colour (according to EN 60204-1)

Main current:	Hovedstrøm:	Huvudström:	400/230VAC
Phase:	Fase:	Fas:	BK
Neutral:	Neutral:	Neutral:	BK
Earth:	Jord:	Jord:	GNYE
Pilot current:	Styrestrøm:	Styrström:	230/24VAC
Phase:	Fase:	Fas:	RD
Neutral:	Neutral:	Neutral:	RD
Earth:	Jord:	Jord:	GNYE
Pilot current:	Styrestrøm:	Styrström:	24VDC
Positive (+):	Positiv (+):	Positiv (+):	BU
Negative (-):	Negativ (-):	Negativ (-):	BU
Unknown potential:	Ukendt potentiale:	Okänd potential:	
All:	Alle:	Alla:	OG

Abbreviations of colours (according to IEC 60757)

Black	Sort	Svart	BK
Brown	Brun	Brun	BN
Red	Rød	Röd	RD
Orange	Orange	Orange	OG
Yellow	Gul	Gul	YE
Green	Grøn	Grön	GN
Blue	Blå	Blå	BU
Light Blue	Lyseblå	Ljusblå	BU
Violet	Violet	Violett	VT
Gray	Grå	Grå	GY
White	Hvid	Vit	WH
Pink	Pink	Rosa	PK
Green/Yellow	Grøn/Gul	Grön/Gul	GNYE
Light-	Lyse-	Ljus-	LT-

Labelling of cables and cores (according to IEC 62491)

Method CL

Method	Description
0	No labelling
A	Use of designated cables or cores
R	Identification labelling by means of reference designation (including cable number)
CL	Local-end connection labelling
CR	Remote-end connection labelling
CB	Both-end connection labelling
S	Signal labelling

Metode	Beskrivelse
0	Ingen mærkning
A	Brug af angivne kabler eller ledere
R	Identifikationsmærkning ved hjælp af referencebetegnelse (inklusive kabelnummer)
CL	Mærkning ved lokal ende
CR	Mærkning ved fjern ende
CB	Mærkning i begge ender
S	Signalmærkning

Metod	Beskrivning
0	Ingen märkning
A	Användning av angivna kablar eller ledare
R	Märkning med referensbeteckning
CL	Lokal anslutningsmärkning
CR	Fjärranslutningsmärkning
CB	Märkning i båda ändar
S	Signalmärkning

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	4
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	2
Drawing number: 2028066	Page Title: Standards	Revision:	F	Scale:	1:1	Next page:	5
		Replaces revision:	D	Format:	A3	Pages in total:	40

Component	Location (en)	Placeringer (da)	Placering (sv)
+A0	Customer connections	Kundetilslutninger	Kundanslutningar
+A1	Control Panel	Styretavle	Kontrollpanel
+A2	Cable connections to AHU aggregate	Kabelforbindelser til ventilationsaggregat	Kabelanslutningar till ventilationsaggregat
+A3	AHU aggregate	Ventilationsaggregat	ventilationsaggregat
+A4	Outside AHU aggregate	Uden for ventilationsaggregat	Utanför ventilationsaggregat
+A5	Coil control box	Styreboks til flader	Batteristyrbox

Component	Object	Examples	Objekt	Eksempler	Objekt	Exempel
-B	Sensing	CO2 & temperature sensors	Føling / Måling	CO2- og temperatursensorer	Avkänning	CO2- & temperaturgivare
-C	Storage	USB drives & application keys	Lagring	USB-drev og applikationsnøgler	Lagring	USB-minnen & applikationsnycklar
-E	Emitting	Electric heaters	Afgivelse	Elektriske varmelegemer	Avgivning	Elvärmare
-F	Protecting	Miniature circuit-breaker	Beskyttelse	Automatsikring	Skydd	Minibrytare
-G	Generating	Circulation pumps	Generering	Cirkulationspumper	Generering	Cirkulationspumpar
-K	Information processing	AHU Controller	Informationsbehandling	AHU-controller	Informationsbehandling	AHU-styrenhet
-M	Driving	Motors	Drivsystem	Motorer	Drivsystem	Motorer
-Q	Controlling	Supply disconnecting device	Kobling / Afbrydelse	Forsyningsadskiller	Koppling / Frånskiljning	Frånskiljare
-R	Restricting	Valves & dampers	Regulering	Ventiler og spjæld	Reglering	Ventiler & spjäll
-S	Human interaction	Touch panel	Betjening	Touchpanel	Mänsklig interaktion	Pekskärm
-T	Transforming	Power supply	Transformering	Strømforsyning	Omvandling	Strömförsörjning
-U	Holding	Cabinet, wire-duct & DIN-rails	Fastgørelse / Indkapsling	Kabinet, kabelkanal og DIN-skinner	Fastsättning / Kapsling	Skåp, kabelkanal & DIN-skenor
-W	Guiding	Cables, wires & tubes	Føring	Kabler, ledninger og rør	Styrning	Kablar, ledare & rör
-X	Interfacing	Terminals & plugs	Grænseflade	Klemmer og stik	Gränssnitt	Plintar & kontakter

(=)	Function	Funktion	Funktion
(+)	Location	Placering	Placering
(-)	Product	Produkt	Produkt
(.)	Sub name	Undernavn	Underbenämning

Principles of structures and reference designations according to ISO/IEC RDS 81346

Principper for strukturer og referencebetegnelser i henhold til ISO/IEC 81346.

Principer för strukturer och referensbeteckningar enligt ISO/IEC RDS 81346

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 5
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 4
Drawing number: 2028066	Page Title: Standards	Revision: F	Scale: 1:1	Next page: 6
		Replaces revision: D	Format: A3	Pages in total: 40

Component	Function (en)	Funktion (da)	Funktion (sv)
-0V	Terminals for 0VDC	Klemmer for 0 VDC	Plintar till 0 VDC
-24V	Terminals for 24VDC	Klemmer for 24 VDC	Plintar till 24 VDC
-B1.1	Extract air temperature	Fralufttemperatur	Frånluftstemperatur
-B1.2	Exhaust air temperature	Afkasttemperatur	Avluftstemperatur
-B2.1	Outdoor air temperature	Udetemperatur	Uteluftstemperatur
-B2.2	Supply airflow temperature correction	Korrektion af tillufttemperatur	Korrigering av tilluftstemperatur
-B3	Heating return water temperature sensor	Temperaturføler for varmereturvand	Temperaturgivare för värmereturvatten
-B4	CO/CW return water temperature sensor	Temperaturføler for CO/CW returvand	Temperaturgivare för CO/CW returvatten
-B5	Outdoor air temperature sensor (Pre-heater)	Udelufttemperaturføler (forvarmeflade)	Utelufttemperaturgivare (förvärmare)
-B6	CO2 sensor	CO2-sensor	CO2-givare
-B7	Duct temperature sensor	Kanaltemperaturføler	Kanaltemperaturgivare
-B8	CO supply water temperature sensor	Fremløbsvandtemperaturføler CO	Framledningstemperaturgivare CO
-B9	Heat recovery temperature	Varmegenvindingstemperatur	Värmeåtervinningstemperatur
-BP1	Dual PTH 1	Dual PTH 1	Dual PTH 1
-BP2	Dual PTH 2	Dual PTH 2	Dual PTH 2
-BP3	Dual PTH 3	Dual PTH 3	Dual PTH 3
-E1	Cabinet heater	Tavlevarme	Skåpvärmare
-E2	Change over coils	Change-over flade	Change-over batteri
-E3	Electric pre-heating	Elektrisk forvarmeflade	Elektriskt förvärmningsbatteri
-E4	Electric post-heating	Elektrisk eftervarmeflade	Elektriskt eftervärmningsbatteri
-F1	MCB for Exhaust air fan	Automatsikring for afkastventilator	Automatsäkring för frånluftsfläkt
-F2	MCB for Supply air fan	Automatsikring for tilluftsventilator	Automatsäkring för tilluftsfläkt
-F3	MCB for Rotor/Control systems	Automatsikring for rotor-/styresystem	Automatsäkring för rotor-/styrsystem
-F4	MCB for Circulation pumps	Automatsikring for cirkulationspumper	Automatsäkring för cirkulationspumpar
-F5	MCB for power analyzer	Automatsikring for effektanalysator	Automatsäkring för effektanalysator
-F10	MCB for Electric post-heating	Automatsikring for elektrisk eftervarmeflade	Automatsäkring för elektriskt eftervärmningsbatteri
-G1	Heating circulation pump	Cirkulationspumpe varme	Värmecirkulationspump
-G2	CW/CO/DX circulation pump	CW/CO/DX cirkulationspumpe	CW/CO/DX cirkulationspump
-K1	AHU Controller	AHU Controller	AHU-styrenhet

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	6
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	5
Drawing number: 2028066	Page Title: Component overview	Revision:	F	Scale:	1:1	Next page:	7
		Replaces revision:	D	Format:	A3	Pages in total:	40

Component	Function (en)	Funktion (da)	Funktion (sv)
-K2	EXT module for Change over	EXT-modul til change-over	EXT-modul för change-over
-K10	Power analyzer main power	Effektanalysator hovedstrøm	Effektanalysator huvudström
-K11	Power analyzer electric heater	Effektanalysator elektrisk eftervarme	Effektanalysator elektrisk eftervärmning
-M1.2	Exhaust air fan	Afkastventilator	Avluftsfläkt
-M2.2	Supply air fan	Tilluftsventilator	Tilluftsfläkt
-M3	Rotor	Rotor	Rotor
-PE1	Earthing terminal block	Jordplint	Jordplint
-Q1	Supply disconnecting device	Forsyningsadskiller	Frånskiljare
-R1.1	Extract air damper (ALC™)	Fraluftspjæld (ALC™)	Frånluftsspjäll (ALC™)
-R1.2	Exhaust air damper	Afkastspjæld	Avluftsspjäll
-R2.1	Outdoor air damper	Udeluftspjæld	Uteluftsspjäll
-R2.2	Supply air damper	Tilluftsspjæld	Tilluftsspjäll
-R3	Bypass damper	Bypass-spjæld	Bypass-spjäll
-R4	Mixing air damper	Blandeluftspjæld	Blandluftsspjäll
-R5	Valve HW	Ventil HW	Ventil HW
-R6	Valve CW	Ventil CW	Ventil CW
-R7	Valve CO/DX	Ventil CO/DX	Ventil CO/DX
-S1	Touch panel	Touchpanel	Pekskärm
-S2	CO system alarm	CO system alarm	Larm för CO-system
-S3	DX control Heat pump	DX-styring varmepumpe	DX-styrning värmepump
-T1	Power supply 230VAC/24VDC	Strømforsyning 230VAC/24VDC	Strömförsörjning 230VAC/24VDC
-T10	Current transformer main power	Strømtransformer hovedstrøm	Strömtransformator huvudström
-T11	Current transformer electric heater	Strømtransformer elektrisk eftervarme	Strömtransformator elektrisk eftervärmning
-U1	Control Panel	Styretavle	Kontrollpanel
-X1.1	Aggregate power plug	Strømstik til aggregat	Strömkontakt aggregat
-X1.2	Aggregate signal plug	Signalstik til aggregat	Signalkontakt aggregat
-X1.3	Modbus splitter 9 x Molex	Modbus-splitter 9 x Molex	Modbus-splitter 9 x Molex
-X1	Aggregate power & signal terminals	Klemmer til aggregatstrøm og signaler	Plintar till aggregatkraft och signaler
-X2	Air dampers terminals	Klemmer til spjæld	Plintar till spjäll

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	7
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	6
Drawing number: 2028066	Page Title: Component overview	Revision:	F	Scale:	1:1	Next page:	8
		Replaces revision:	D	Format:	A3	Pages in total:	40

Component	Function (en)	Funktion (da)	Funktion (sv)
-X3	Pre-HE signal terminals	Klemmer til forvarmefladesignaler	Plintar till förvärmningsbatterisignaler
-X4	Electric post-heating terminals	Klemmer til elektrisk eftervarmeflade	Plintar till elektriskt eftervärmningsbatteri
-X5	HW - Power & signal terminals	Klemmer til HW-strøm og signal	Plintar till HW kraft och signal
-X6	CW/CO - Power & signal terminals	Klemmer til CW/CO-strøm og signal	Plintar till CW/CO kraft och signal
-X7	Temperature & CO2 sensors terminals	Klemmer til temperatur- og CO2-sensorer	Plintar till temperatur- och CO2-givare
-X8	Customer connections terminals	Klemmer til kundetilslutning	Plintar till kundanslutning
-X9	Power analyzer terminals	Klemmer til effektanalysator	Plintar till effektanalysator
-X10	Modbus splitter 4 x RJ12	Modbus-splitter 4 x RJ12	Modbus-splitter 4 x RJ12
-X51	CO/DX MODBUS & signal terminals	CO/DX MODBUS- og signalklemmer	CO/DX MODBUS- och signalplintar
-X52	CO/DX Power & signal terminals	CO/DX strøm- og signalklemmer	CO/DX kraft- och signalplintar
-X-B3	Heating return water temperature sensor plug	Stik til føler for varmereturvand	Kontakt för temperaturgivare till värmereturvatten
-X-E4.2	Electric heating plug	Stik til elektrisk varmeflade	Kontakt för elektriskt värmebatteri
-X-M1.2	Exhaust air fan plug	Stik til afkastventilator	Kontakt för avluftsfläkt
-X-M2.2	Supply air fan plug	Stik til tilluftsventilator	Kontakt för tilluftsfläkt
-X-M3	Rotor plug	Stik til rotor	Kontakt för rotor
-X-R1.1	Extract air damper (ALC™) plug	Stik til fraluftspjæld (ALC™)	Kontakt för frånluftsspjäll (ALC™)
-X-R1.2	Exhaust air damper plug	Stik til afkastspjæld	Kontakt för avluftsspjäll
-X-R2.1	Outdoor air damper plug	Stik til udeluftspjæld	Kontakt för uteluftsspjäll
-X-R2.2	Supply air damper plug	Stik til tilluftsspjæld	Kontakt för tilluftsspjäll
-X-R3	Bypass damper plug	Stik til bypass-spjæld	Kontakt för bypass-spjäll
-X-R4	Mixing air damper plug	Stik til blandeluftspjæld	Kontakt för blandluftsspjäll

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 8
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 7
Drawing number: 2028066	Page Title: Component overview	Revision: F	Scale: 1:1	Next page: 9
		Replaces revision: D	Format: A3	Pages in total: 40

Principles

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	Principles
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	8
Drawing number: 2028066	Page Title: Principles	Revision:	F	Scale:	1:1	Next page:	9
		Replaces revision:	D	Format:	A3	Pages in total:	40

COUNTER-FLOW



ROTOR



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor: DKTSA	Page: 9
		Revision date:	17-08-2026	Approved by: DKBP	Previous page: 8
Drawing number: 2028066	Page Title: Principles for all configuration options	Revision:	F	Scale: 1:5	Next page: 10
		Replaces revision:	D	Format: A3	Pages in total: 40

Arrangement drawings

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	Arrangement
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	9
Drawing number: 2028066	Page Title: Arrangement drawings	Revision:	F	Scale:	1:1	Next page:	10
		Replaces revision:	D	Format:	A3	Pages in total:	40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	10
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	9
Drawing number: 2028066	Page Title: Basic control panel 3x400V	Revision:	F	Scale:	1:3	Next page:	11
		Replaces revision:	D	Format:	A3	Pages in total:	40

Supplementary selections

Option 1: Power supply Electric heater (HE)

-F10 Circuit breaker 4P
-X4 Wire terminals

Option 2: Power analyser Main power (PAM)

-K10 Three-phase power analyser
-T10 Three-phase current transformers 125A
-F5 Circuit breaker 4P C2A

Option 3: Power analyser Electric heater (PAH)

-K11 Three-phase power analyser
-T11 Three-phase current transformers 63A

Option 3 is not selectable without option 1 and 2.

Option 4: Control panel heater

-E1 Control panel heater





Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	11
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	10
Drawing number: 2028066	Page Title: Supplementary selections	Revision:	F	Scale:	1:3	Next page:	12
		Replaces revision:	D	Format:	A3	Pages in total:	40









-X1:01	-M1.2	Exhaust air fan	L
-X1:02	-M1.2	Exhaust air fan	N
-X1:03	-M1.2	Spare	-
-X1:04	-M2.2	Supply air fan	L
-X1:05	-M2.2	Supply air fan	N
-X1:06	-M2.2	Spare	-
-X1:07	-M3	Rotor	L
-X1:08	-M3	Rotor	N
-X1:09	-MB	Modbus	0V
-X1:10	-MB	Modbus	24V
-X1:11	-MB	Modbus	B-
-X1:12	-MB	Modbus	A+
-X1:13	-E4	Electric post-heating	0-10V
-X1:14	-E4	Electric post-heating	GND
-X1:15	-E4	Electric post-heating	Fire
-X1:16	-E4	Electric post-heating	Fail
-X1:17	-E4	Electric post-heating	Run OK
-X1:18	-E4	Electric post-heating	Run OK
-X1:19	-B3	Temperature sensor	-
-X1:20	-B3	Temperature sensor	-
-X1:PE	-PE	Protective Earth	PE

-X2:01	-R1.1	Extract air damper	0V
-X2:03	-R1.1	Extract air damper	24V
-X2:05	-R1.1	Extract air damper	B-
-X2:07	-R1.1	Extract air damper	A+
-X2:02	-R2.2	Supply air damper	0V
-X2:04	-R2.2	Supply air damper	24V
-X2:06	-R2.2	Supply air damper	B-
-X2:08	-R2.2	Supply air damper	A+
-X3:01	-E3	Electric pre-heating	0-10V
-X3:02	-E3	Electric pre-heating	GND
-X3:03	-E3	Electric pre-heating	Fire
-X3:04	-E3	Electric pre-heating	Fail
-X3:05	-E3	Electric pre-heating	Run OK
-X3:06	-E3	Electric pre-heating	Run OK
-X4:01	-E4	PWR Electric heating	L1
-X4:02	-E4	PWR Electric heating	L2
-X4:03	-E4	PWR Electric heating	L3
-X4:04	-E4	PWR Electric heating	N
-X4:PE	-E4	PWR Electric heating	PE

-X5:01	-R1	Valve HW	0V
-X5:02	-R1	Valve HW	24V
-X5:03	-R1	Valve HW	Signal
-X5:04	-R1	Valve HW	Not used
-X5:05	-G1	HW circulation pump	NC
-X5:06	-G1	HW circulation pump	COM
-X5:07	-G1	HW circulation pump	L
-X5:08	-G1	HW circulation pump	N
-X5:PE	-G1	HW circulation pump	PE
-X6:01	-R2	Valve CW/CO	0V
-X6:02	-R2	Valve CW/CO	24V
-X6:03	-R2	Valve CW/CO	Signal
-X6:04	-R2	Valve CW/CO	Not used
-X6:05	-G2	CW/CO circulation pump	NC
-X6:06	-G2	CW/CO circulation pump	COM
-X6:07	-G2	CW/CO circulation pump	L
-X6:08	-G2	CW/CO circulation pump	N
-X6:PE	-G2	CW/CO circulation pump	PE

-X7:01	-B5	Pre-heater temperature sensor	-
-X7:02	-B5	Pre-heater temperature sensor	-
-X7:03	-B6	CO2 sensor	GND
-X7:04	-B6	CO2 sensor	OUT
-X7:05	-B6	CO2 sensor	+VCC
-X7:06	-	Spare terminal	
-X7:07	-B7	Duct temperature sensor	-
-X7:08	-B7	Duct temperature sensor	-

-X8:0V	Customer connections	24V power supply
-X8:24V	Customer connections	24V power supply
-X8:01	Customer connections	Fire alarm input
-X8:02	Customer connections	Fire alarm input
-X8:03	Customer connections	Option input 1
-X8:04	Customer connections	Option input 1
-X8:05	Customer connections	Option input 2
-X8:06	Customer connections	Option input 2
-X8:07	Customer connections	Option input 3
-X8:08	Customer connections	Option input 3
-X8:09	Customer connections	Option input 4
-X8:10	Customer connections	Option input 4
-X8:11	Customer connections	A alarm output
-X8:12	Customer connections	A alarm output
-X8:13	Customer connections	Option output 1
-X8:14	Customer connections	Option output 1
-X8:15	Customer connections	Option output 2
-X8:16	Customer connections	Option output 2
-X8:17	Customer connections	BMS - RS485
-X8:18	Customer connections	BMS - RS485
-X8:19	Customer connections	Start signal
-X8:20	Customer connections	Start signal

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor: DKTSA	Page: 12
		Revision date:	17-08-2026	Approved by: DKBP	Previous page: 11
Drawing number: 2028066	Page Title: Control panel terminals	Revision:	F	Scale: 1:1	Next page: 20
		Replaces revision:	D	Format: A3	Pages in total: 40

Circuit diagrams

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	Circuit diagrams
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	12
Drawing number: 2028066	Page Title: Circuit diagrams	Revision:	F	Scale:	1:1	Next page:	20
		Replaces revision:	D	Format:	A3	Pages in total:	40



Manufactured by:	Project:	Start date:	01-06-2023	Constructor:	DKTSA	Page:	20
EXHAUSTO	VEX1000 - Customized (1x230VAC FANS)	Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	12
Drawing number:	Page Title:	Revision:	F	Scale:	1:1	Next page:	21
2028066	Main current	Replaces revision:	D	Format:	A3	Pages in total:	40



24VDC supply

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	21
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	20
Drawing number: 2028066	Page Title: Power analyzers - 3 phase	Revision:	F	Scale:	1:1	Next page:	22
		Replaces revision:	D	Format:	A3	Pages in total:	40



24VDC supply

Control panel heater

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 22
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 21
Drawing number: 2028066	Page Title: Pilot current	Revision: F	Scale: 1:1	Next page: 23
		Replaces revision: D	Format: A3	Pages in total: 40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 23
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 22
Drawing number: 2028066	Page Title: Standard - Modbus connections	Revision: F	Scale: 1:1	Next page: 24
		Replaces revision: D	Format: A3	Pages in total: 40

+A1

Rotor drive option

Counter-flow option

+A3



Exhaust air fan
Control



Supply air fan
Control



Rotor drive



Bypass damper

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 24
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 23
Drawing number: 2028066	Page Title: Standard - Fan & Rotor/Bypass controls	Revision: F	Scale: 1:1	Next page: 25
		Replaces revision: D	Format: A3	Pages in total: 40

0	1	2	3	4	5	6	7	8	9

+A1

+A3



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 25	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 24	
Drawing number: 2028066	Page Title: Standard - Dampers	Revision: F	Scale: 1:1	Next page: 26	
		Replaces revision: D	Format: A3	Pages in total: 40	

0	1	2	3	4	5	6	7	8	9

+A1

/23.7 A+
/23.7 B-
/23.7 24V.2
/23.7 0V.2

-X2 1 3 5 7 -X2 2 4 6 8

+A3

-X1.3 8

-X-R4 1 2 3 4 5 6

BK RD WH OG PK GY

1- 2+ 3Y 5U 6C1 7C2

-R4 M
Modbus: 132

Mixing air damper

+A4

-W-R1.1 1 2 3 4

-X-R1.1 1 2 3 4 5 6

BK RD WH OG PK GY

1- 2+ 3Y 5U 6C1 7C2

-R1.1 M
Modbus: 136

(ALC™ air damper)
Extract air damper

-X-R2.2 1 2 3 4 5 6

BK RD WH OG PK GY

1- 2+ 3Y 5U 6C1 7C2

-R2.2 M
Modbus: 135

Supply air damper

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 26	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 25	
Drawing number: 2028066	Page Title: Options - Dampers	Revision: F	Scale: 1:1	Next page: 27	
		Replaces revision: D	Format: A3	Pages in total: 40	



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	27
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	26
Drawing number: 2028066	Page Title: Options - Pre-heating controls	Revision:	F	Scale:	1:1	Next page:	28
		Replaces revision:	D	Format:	A3	Pages in total:	40



External power supply

Electric post-heating

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 28
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 27
Drawing number: 2028066	Page Title: Options - Post-heating controls	Revision: F	Scale: 1:1	Next page: 29
		Replaces revision: D	Format: A3	Pages in total: 40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 29
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 28
Drawing number: 2028066	Page Title: Options - HW/CW/CO controls	Revision: F	Scale: 1:1	Next page: 30
		Replaces revision: D	Format: A3	Pages in total: 40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	30
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	29
Drawing number: 2028066	Page Title: Options - Temperature & CO2 sensors	Revision:	F	Scale:	1:1	Next page:	31
		Replaces revision:	D	Format:	A3	Pages in total:	40



IO	Default setting	Comment
Digital input 6	Fire alarm	Mandatory
Universal input 1 - Option 1	External High Speed mode	-
Universal input 2 - Option 2	External Medium Speed mode	Can change depending on the coil configuration
Universal input 3 - Option 3	External Low Speed mode	Can change depending on the coil configuration
Universal input 4 - Option 4	External resetting of alarms	Can change depending on the coil configuration
Digital output 5	"A" alarm	Mandatory
Digital output 6 - Option 1	User relay	-
Digital output 7 - Option 2	Operating relay	-
RS485	Modbus BMS	-
Digital input 7	External Start signal	Mandatory

For further information on connecting accessories, see document 3006851

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	31
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	30
Drawing number: 2028066	Page Title: Standard - Customer connections	Revision:	F	Scale:	1:1	Next page:	40
		Replaces revision:	D	Format:	A3	Pages in total:	40

Pressure & temperature transmitters

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	PTH
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	31
Drawing number: 2028066	Page Title: Pressure & temperature transmitters	Revision:	F	Scale:	1:1	Next page:	40
		Replaces revision:	D	Format:	A3	Pages in total:	40

0	1	2	3	4	5	6	7	8	9

+A3

-BP1 Dual PTH 1

DualPTH 6202-2

-BP1 RS485 A

Modbus A In

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 A

-W-K2

-X1.3 6

-BP1 RS485 B

Modbus B Out

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 B

-BP1 Temp. 1

Exhaust air temperature

Dual PTH

1 2

-W-B1.2 BK WH

BK WH

-B1.2 t°

Exhaust air temperature

-BP1 Temp. 2

(Pre-heater coil temperature)
Outdoor air temperature

Dual PTH

3 4

-W-B2.1 BK WH

BK WH

-B2.1 t°

(Pre-heater coil temperature)

Outdoor air temperature

-BP1 Air pressure 1

Exhaust air fan pressure

Dual PTH

- +

GY YE

- +

Exhaust air fan pressure

-BP1 Air pressure 2

Outdoor air filter pressure

Dual PTH

- +

BU RD

- +

Outdoor air filter pressure

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 40	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 31	
Drawing number: 2028066	Page Title: Standard - Dual PTH 1	Revision: F	Scale: 1:1	Next page: 41	
		Replaces revision: D	Format: A3	Pages in total: 40	

0	1	2	3	4	5	6	7	8	9

+A3

-BP2 Dual PTH 2

DualPTH 6202-2

-BP2 RS485 A

Modbus A In

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 A

-W-K3

-X1.3 7

-BP2 RS485 B

Modbus B Out

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 B

-BP2 Temp. 1

Supply airflow correction

Dual PTH

1 2

-W-B2.2 BK WH

BK WH

-B2.2 t°

Supply airflow correction

-BP2 Temp. 2

Extract air temperature

Dual PTH

3 4

-W-B1.1 BK WH

BK WH

-B1.1 t°

Extract air temperature

-BP2 Air pressure 1

Supply air fan pressure

Dual PTH

- +

GY YE

- +

Supply air fan pressure

-BP2 Air pressure 2

Extract air filter pressure

Dual PTH

- +

BU RD

- +

Extract air filter pressure

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 41	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 40	
Drawing number: 2028066	Page Title: Standard - Dual PTH 2	Revision: F	Scale: 1:1	Next page: 42	
		Replaces revision: D	Format: A3	Pages in total: 40	

0	1	2	3	4	5	6	7	8	9

+A3

Rotor drive option

-BP3 Dual PTH 3

DualPTH 6202-2

-BP3 RS485 A

Modbus A In

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 A

-W-K4

-PB3

/24.7

-BP3 RS485 B

Modbus B Out

1	2	3	4	5	6
V+	GND	BUS B	BUS A	V+	GND

Dual PTH

RJ12 B

-BP3 Temp. 1

Heat recovery temperature

Dual PTH

1 2

-W-B9

BK WH

BK WH

-B9

t°

Heat recovery temperature

-BP3 Temp. 2

Spare

Dual PTH

1 2

-BP3 Air pressure 1

Automatic Leakage Control™

Dual PTH

- +

GY YE

- +

Extract air Supply air

Automatic Leakage Control™

-BP3 Air pressure 2

Rotor deicing

Dual PTH

- +

BU RD

- +

Exhaust air Extract air

Rotor deicing

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 42	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 41	
Drawing number: 2028066	Page Title: Option - ALC™ - Rotor deicing - Heat recovery temp.	Revision: F	Scale: 1:1	Next page: 43	
		Replaces revision: D	Format: A3	Pages in total: 40	

0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9

+A3

Counter-flow option

-BP3 Dual PTH 3 — DualPTH 6202-2

-BP3 RS485 A — Modbus A In (1 V+, 2 GND, 3 BUS B, 4 BUS A, 5 V+, 6 GND) — Dual PTH

-BP3 RS485 B — Modbus B Out (1 V+, 2 GND, 3 BUS B, 4 BUS A, 5 V+, 6 GND) — Dual PTH

-BP3 Temp. 1 — Heat recovery temperature — Dual PTH

-BP3 Temp. 2 — Spare — Dual PTH

-BP3 Air pressure 1 — Space — Dual PTH

-BP3 Air pressure 2 — Counter-flow deicing — Dual PTH

RJ12 A

RJ12 B

Temp. 1: 1, 2

Temp. 2: 3, 4

Air pressure 1: -, +

Air pressure 2: -, +

-W-K5

-X1.3 — 8

-W-B9 — BK, WH

-B9 — t°

Heat recovery temperature

Air pressure 2: BU, RD — Exhaust air -, + Extract air

Counter-flow deicing

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 43	
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 42	
Drawing number: 2028066	Page Title: Option - Counter-flow deicing - Heat recovery temp.	Revision: F	Scale: 1:1	Next page: 50	
		Replaces revision: D	Format: A3	Pages in total: 40	

Option - Coil control box

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	Coil control box
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	43
Drawing number: 2028066	Page Title: Option - Coil control box	Revision:	F	Scale:	1:1	Next page:	50
		Replaces revision:	D	Format:	A3	Pages in total:	40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 50
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 43
Drawing number: 2028066	Page Title: Option - Coil control box layout	Revision: F	Scale: 1:1	Next page: 51
		Replaces revision: D	Format: A3	Pages in total: 40

0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9

+A5

-K2 EXcon EXT — 5 — EXcon EXT

-K2 RS485 A — Modbus A In (1 V+, 2 GND, 3 BUS B-, 4 BUS A+, 5 V+, 6 GND) — EXcon EXT

-K2 RS485 B — Modbus B Out (1 V+, 2 GND, 3 BUS B-, 4 BUS A+, 5 V+, 6 GND) — EXcon EXT

-K2 AO2 — CO Valve — EXcon EXT — 1, 2

-K2 Temp. 1 — CO return water temperature — EXcon EXT — 11, 12

-K2 DO1 — Heating selected — EXcon EXT — 13, 14

-K2 DO2 — Cooling selected — EXcon EXT — 15, 16

-K2 DI1 — System alarm — EXcon EXT — 17, 18

-K2 Temp. 2 — CO supply water temperature — EXcon EXT — 21, 22

RJ12 A

RJ12 B

-W-K2 (WH/GY GND, BN/PK 24V+, GN BUS B-, YE BUS A+)

-X51: 1 GND, 2 24V+, 3 B-, 4 A+, 5 AO

-X52: 1 NC, 2 COM, 3 L, 4 N, PE

+A0

+A1

-W-K2 — Cable by others — K2 /22.8 -X10 — Min. 0,75 mm²

-W-G2 — Cable by others — -X6: 5, 6, 7, 8, PE — Min. 1,50 mm²

-W-R7 (1 BK 1-, 2 RD 2+, 3 WH 3Y, 5 OG 5U) — -R7 M — CO Valve

-W-G2 (NC, COM, L, N, PE, GNYE) — -G2 M 1~ — CW/CO circulation pump

-W-B4 (BK, WH) — -B4 t° — CO return water temperature sensor

-W-E2 (1, 2, 3, 4) — -E2 — CO Heating selected

-E2 — CO Cooling selected

-W-S2 (1, 2) — -S2 — CO System alarm

-W-B8 (BK, WH) — -B8 t° — CO supply water temperature sensor

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor: DKTSA	Page: 51
		Revision date:	17-08-2026	Approved by: DKBP	Previous page: 50
Drawing number: 2028066	Page Title: Option - Combi Coil	Revision:	F	Scale: 1:1	Next page: 52
		Replaces revision:	D	Format: A3	Pages in total: 40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 52
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 51
Drawing number: 2028066	Page Title: Option - Direct Expansion Heat pump	Revision: F	Scale: 1:1	Next page: 53
		Replaces revision: D	Format: A3	Pages in total: 40



Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date: 01-06-2023	Constructor: DKTSA	Page: 53
		Revision date: 17-08-2026	Approved by: DKBP	Previous page: 52
Drawing number: 2028066	Page Title: Option - Direct Expansion Cooling	Revision: F	Scale: 1:1	Next page: PARTS
		Replaces revision: D	Format: A3	Pages in total: 40

Article no.	Type	Description	Manufacturer	Quantity
3606480440496	A9F04210	Miniature Circuit Breaker iC60N C 10A 2P	Schneider Electric	4
3606480440755	A9F04402	Miniature Circuit Breaker iC60N C 2A 4P	Schneider Electric	1
3606480440823	A9F04420	Miniature Circuit Breaker iC60N C 20A 4P	Schneider Electric	1
3606480440830	A9F04425	Miniature Circuit Breaker iC60N C 25A 4P	Schneider Electric	1
3606480440854	A9F04440	Miniature Circuit Breaker iC60N C 40A 4P	Schneider Electric	1
4251823467457	CSF 060 50W	Enlcosure heater, 120-240V AC 50W with thermostat	STEGO	1
4711287434650	LRS-75-24	Power supply 230VAC/24VDC	MEAN WELL	1
5705100101361	2077-0000	Earth clamp Cu-mini 7 pole	Cubic	1
6417019393094	OT63F4N2	OT63F4N2 Supply disconnector 3P+N 63A	ABB	1
6417019102641	OTS63T1	OTS63T1 Terminal shroud 1P	ABB	1
6417019102627	OTS63T3	OTS63T3 Terminal shroud 3P	ABB	1
6417019415604	OHBS2AJ	OHBS2AJ Handle	ABB	1
6417019449500	OX6X115	OX6X115 Supply disconnector Shaft 115mm	ABB	1
6417019393834	OTPE80FP	OTPE80FP Earth terminal	ABB	1
8433059084073	MC3-63	Three-phase current transformer, 63 A	Circutor	1
8433059084080	MC3-125	Three-phase current transformer, 125 A	Circutor	1
8433059279288	CVM-E3-MINI-MC-485-IC	Three-phase power analyzer for mounting on DIN rail	Circutor	2
EXno.:2019904	MODBUS split 4xRJ12	MODBUS splitter 4x RJ12 connectors, 2x terminal rows	EXHAUSTO	1
EXno.:2027468	EXcon+	AHU Controller	EXHAUSTO	1

Manufactured by: EXHAUSTO	Project: VEX1000 - Customized (1x230VAC FANS)	Start date:	01-06-2023	Constructor:	DKTSA	Page:	PARTS
		Revision date:	17-08-2026	Approved by:	DKBP	Previous page:	53
Drawing number: 2028066	Page Title: Active components part list -A1	Revision:	F	Scale:	1:5	Next page:	.
		Replaces revision:	D	Format:	A3	Pages in total:	40

Scan code and go to addresses at
www.exhausto.dk

EXHAUSTO